

**Commonwealth of Virginia
Uniform Water Well Completion Report**

Owner Rodney Gaines
 Address 84 Courage Ln.
Stafford, VA
 Phone 221-4336
 Location Rock Hill Est. - Lot # 2

Tax Map ID 90-1-2
 VDH Permit SWP-96-354
 WVCB Permit _____
 WVCB ID _____
 County Stafford

* Well Data *

General Information

Drilling Method Air Rotary
 Depth to Bedrock 83'
 Static Water Level 10'
 Well Disinfected (Y or N) N

Date Completed 3-24-97
 Yield 1 (GPM)
 Stabilized Water Level N/A
 Disinfectant Used N/A

Total Depth of Well 405'
 Length of Test N/A
 Natural Flow (Rate) Y
 Amount Used N/A

Casing

From +1 To 87'
 Size 6" Material PVC
 Weight/Schedule 40

From _____ To _____
 Size _____ Material _____
 Weight/Schedule _____

From _____ To _____
 Size _____ Material _____
 Weight/Schedule _____

Gravel Pack

From N/A To _____

From _____ To _____

From _____ To _____

Grout

From 0 To 65'
 Bore Hole Size 10"
 Type bentonite
 Method pressure

From _____ To _____
 Bore Hole Size _____
 Type _____
 Method _____

From _____ To _____
 Bore Hole Size _____
 Type _____
 Method _____

Water Zones or Screened Intervals

From 90'? To 365'?
 Mesh Size _____ Diam _____
 From _____ To _____
 Mesh Size _____ Diam _____

From _____ To _____
 Mesh Size _____ Diam _____
 From _____ To _____
 Mesh Size _____ Diam _____

From _____ To _____
 Mesh Size _____ Diam _____
 From _____ To _____
 Mesh Size _____ Diam _____

* Use Data *

Private Well: Domestic Agricultural _____ Industrial _____ Monitoring _____
 Public Well: Community _____ Non Community _____

* Abandonment Information *

Bored or Dug Wells

Casing Removed, Y or N? _____
 If Y, Depth to which casing was removed: _____
 Depth and Type of Fill: _____
 Source of Fill _____
 Bentonite Plugs: From _____ to _____ From _____ to _____

Wells Other than Bored Wells

Casing Removed, Y or N? _____
 Depth to which casing was removed: _____
 Applicable, depth(s), and type of gravel/sand fill: _____
 Source of gravel or sand: _____
 Cement: From _____ to _____ From _____ to _____

Method of permanently marking location: _____

Drillers Log

Depth
0'-45'
45'-83'
83'-405'

Description of Formation or Sediment
brown sandy clay
SAND
granite

Remarks
WTCC-6P
well cap

(Use additional sheets if necessary)

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complied with all applicable state and local regulations, ordinances and laws.

Name Water Wells Inc
Address P.O. Box 491
Mineral, VA 23117
Phone 894-5444

Drillers Signature Gregory L. Hatfield
Date 3-24-97 Representing

Virginia Contractors License Number 031685