

SWC Permit _____
 County Permit _____
 Certification of inspecting official:
 This well does _____ does not
 meet code/low requirements.
 S. _____
 Date _____
 For Office Use

County/City Stafford County

County/City Stamp

• Virginia Plane Coordinates
 _____ N
 _____ E
 Latitude & Longitude
 _____ N
 _____ W
 • Topo. Map No. _____
 • Elevation _____ ft.
 • Formation _____
 • Lithology _____
 • River Basin _____
 • Province _____
 • Type Logs _____
 • Cuttings _____
 • Water Analysis _____
 • Aquifer Test _____

• Owner Hhalid Hussain /H. Associates
 • Well Designation or Number _____
 Address 4103 Bixby Court
Chantilly, VA, 22021
 Phone 378-6575
 • Drilling Contractor Van's Const. Co., Inc.
 Address P.O. Box 3306
Fredericksburg, VA, 22402
 Phone 373-7502

189-87-294
 Tax Map I.D. No. 20H-2-30
 Subdivision Bald Eagle Hills
 Section 2
 Block _____
 Lot 30
 Class Well: I _____, IIA _____
 IIB X, IIIA _____, IIIB _____
 IIIC _____, IIID _____, IIIE _____

WELL LOCATION: _____ (feet/miles _____ direction) of _____
 and _____ (feet/miles _____ direction) of _____
 (If possible please include map showing location marked)

Date started 2-19-88 • Date completed 2-22-88 Type rig Rotary

1. WELL DATA: New Reworked _____ Deepened _____

• Total depth 180 ft.
 • Depth to bedrock _____ ft.
 • Hole size (Also include reamed zones)
 • 12 inches from 0 to 58 ft.
 • 6 inches from 58 to 180 ft.
 • _____ inches from _____ to _____ ft.
 • Casing size (I.D.) and material
 • 6 inches from 0 to 58 ft.
 Material steel
 Wt. per foot _____ or wall thickness _____ in.
 • _____ inches from _____ to _____ ft.
 Material _____
 Wt. per foot _____ or wall thickness _____ in.
 • _____ inches from _____ to _____ ft.
 Material _____
 Wt. per foot _____ or wall thickness _____ in.
 • Screen size and mesh for each zone (where applicable)
 • _____ inches from _____ to _____ ft.
 • Mesh size _____ Type _____
 • _____ inches from _____ to _____ ft.
 • Mesh size _____ Type _____
 • _____ inches from _____ to _____ ft.
 • Mesh size _____ Type _____
 • _____ inches from _____ to _____ ft.
 • Mesh size _____ Type _____
 • Gravel pack
 • From _____ to _____ ft.
 • From _____ to _____ ft.
 • Grout
 • From 50 to 0 ft., Type pressure
 • From _____ to _____ ft., Type _____

2. WATER DATA • Water temperature _____ of _____

• Static water level (unpumped level-measured) 30 ft.
 • Stabilized measured pumping water level _____ ft.
 • Stabilized yield 20 gpm after 2 hours
 Natural Flow: Yes _____ No X, flow rate: _____ gpm
 Comment on quality clear
 3. WATER ZONES: From 60 To 65
 From 90 To 105 From 165 To 170
 From _____ To _____ From _____ To _____
 4. USE DATA:
 Type of use: Drinking X, Livestock Watering _____
 Irrigation _____, Food processing _____, Household X
 Manufacturing _____, Fire safety _____, Cleaning _____
 Recreation _____, Aesthetic _____, Cooling or heating _____
 Injection _____, Other _____
 • Type of facility: Domestic X, Public water supply _____
 Public institution _____, Farm _____, Industry _____
 Commercial _____, Other _____
 5. PUMP DATA: Type sub. • Rated H.P. 1/2
 • Intake depth 140 • Capacity 10 at 230 head
 6. WELLHEAD: Type well seal pitless
 Pressure tank 42 gal. Loc. house
 Sample tap X, Measurement port X
 Well vent X, Pressure relief valve X
 Gate valve X, Check valve (when required) X
 Electrical disconnect switch on power supply X
 7. DISINFECTION: Well disinfected X yes _____ no _____
 Date 2-23-88, Disinfectant used chl. tabl.
 Amount _____, Hours used _____
 8. ABANDONMENT (where applicable) • yes _____ no _____
 Casing pulled yes _____ no _____ not applicable _____
 Plugging grout From _____ to _____ material _____

9. State law requires submitting to the Virginia State Water Control Board information about groundwater and wells for every well intended for water, or any other non-exempt well. This information must be submitted whether the well is completed, on stand-by, or in the process of construction. Information required includes: an accurately and completely prepared water well completion report, full data from any aquifer pump-out cuttings taken at ten foot intervals (unless exemption is secured), the results of any chemical analyses, and copies of any geophysical logs. For public supply wells, pumpage and use reports are required from owners of public supply and industrial wells. County or State permits to drill may be required in some parts of the state. Some counties require submission of a water well completion report. The Virginia State Health Department requires a water well completion report for public supply wells.

10. DRILLERS LOG (use additional Sheets if necessary)

| 10. DRILLERS LOG (use additional Sheets if necessary) | | | 11. | 12. DIAGRAM OF WELL CONSTRUCTION (with dimensions) |
|---|-----|--|--|--|
| DEPTH (feet) | | TYPE OF ROCK OR SOIL (color, material, fossils, hardness, etc.) | REMARKS (water, caving, cavities, broken, core, shot, etc.) | Drilling Time (Min.) |
| From | To | | | |
| 0 | 58 | clay/ soft rock | | |
| 58 | 80 | soft rock (muddy) | | |
| 80 | 155 | granite w/voids | | |
| 155 | 180 | slate quantico w/voids | | |

13. Well lot dedicated? _____; Size _____ ft. X _____ ft.; Well house? _____
 Distance to nearest pollutant source _____ ft., Type _____
 Distance to nearest property line _____ ft., Building _____ ft.

14. WATER SERVICE PIPE: Checked under _____ 60 _____ p.s.i. for _____ 10 _____ minutes. Pipe size _____ 1 _____ inches, Material _____ plastic _____
 Installer _____ Van's Const. Co., Inc. _____
 Date _____ 2-23-88 _____

15. I certify that the information contained herein is true and correct and that this well and/or system has been installed and constructed in accordance with the requirements for well construction as specified in compliance with appropriate county or independent city ordinances and the laws and rules of the Commonwealth of Virginia.

State Water Control Board Regional Offices

Valley Reg. Off.
 116 North Main Street
 P. O. Box 268
 Bridgewater, Va. 22812
 703-828-2595

Piedmont Reg. Off.
 4010 West Broad Street
 P. O. Box 6616
 Richmond, Va. 23230
 804-257-1006

Southwest Reg. Off.
 408 East Main Street
 P. O. Box 476
 Abingdon, Va. 24210
 703-626-5183

Tidewater Reg. Off.
 287 Pembroke Office Park
 Suite 310 Pembroke No. 2
 Va. Beach, Va. 23462
 804-499-8742

West Central Reg. Off.
 Executive Park
 3312 Peters Creek Road
 Roanoke, Va. 24019
 703-982-7432

Northern Virginia Reg. Off.
 5515 Cherokee Avenue
 Suite 404
 Alexandria, Va. 22312
 703-750-9111

Signature _____ Sue Shelburne _____ (Seal), Date _____ 2-25-88 _____
 (Well driller or authorized person) License No. _____