

Commonwealth of Virginia
Uniform Water Well Completion Report

Owner Richard Smith
Address 514 Waterberry Drive
Fredericksburg, VA 22405
Phone _____
Location Lot #3 W. Don Moore

Tax Map ID 26-21B
VDH Permit SWP-96-123
WVCB Permit _____
WVCB ID _____
County Stafford

* Well Data *

General Information

Drilling Method Air rotary Date Completed 7-17-96 Total Depth of Well 305'
Depth to Bedrock 30' Yield 50 (GPM) Length of Test 2 hr
Static Water Level 25' Stabilized Water Level _____ Natural Flow (Rate) _____
Well Disinfected (Y or N) N Disinfectant Used _____ Amount Used _____

Casing

From +1 To 67 From _____ To _____
Size 6 1/2 Material PVC Size _____ Material _____
Weight/Schedule Sch 40 Weight/Schedule _____

Gravel Pack

From 67 To 50 From _____ To _____

Grout

From 50 To 0 From _____ To _____
Bore Hole Size 10" Bore Hole Size _____ Bore Hole Size _____
Type Neat Type _____ Type _____
Method Pressure Method _____ Method _____

Water Zones or Screened Intervals

From 125 To 130 From 225 To 230 From 280 To 285
Mesh Size _____ Diam _____ Mesh Size _____ Diam _____ Mesh Size _____ Diam _____
From _____ To _____ From _____ To _____ From _____ To _____
Mesh Size _____ Diam _____ Mesh Size _____ Diam _____ Mesh Size _____ Diam _____

* Use Data *

Private Well: Domestic Agricultural _____ Industrial _____ Monitoring _____
Public Well: Community _____ Non Community _____

* Abandonment Information *

Bored or Dug Wells

Casing Removed, Y or N?: _____
If Y, Depth to which casing was removed: _____
Depth and Type of Fill: _____
Source of Fill _____
Bentonite Plugs: From _____ to _____ From _____ to _____

Wells other than Bored Wells

Casing removed, Y or N? _____
Depth to which casing was removed: _____
Applicable, depth(s), and type of gravel/sand fill: _____
Source of gravel or sand: _____
Cement: From _____ to _____ From _____ to _____

Method of permanently marking location: _____

* Drillers Log *

Depth	Description of Formation or Sediment	Remarks
0-30	Clay	Brown
30-80	Rock	Brown shale
80-305	Rock	Granite w/ voids



$$\begin{array}{r}
 1470 \\
 \times 2\frac{1}{2} \\
 \hline
 29400
 \end{array}$$

(User additional Sheets if necessary)

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Name VAN'S CONSTRUCTION CO., INC.

Address PO BOX 3306

FREDERICKSBURG, VA 22402

Phone (540) 373-7502

Drillers Signature Bill Van Hey
 Date 7-17-96 Representing VAN'S CONSTRUCTION CO., INC.

Virginia Contractors License Number 2701-018610A