

Commonwealth of Virginia Uniform Water Well Completion Report

Gerald & Kimberly Hoy

1487 Garrisonville Rd
Stafford, Va/
Lot #374 Mt. Olive Road

Tax Map ID 27-37A
VDH Permit WS-93-20
WVCB Permit
WVCB ID
County Stafford

* Well Data *

General Information

Method Air rotary
Bedrock 107
Water Level 30
Disinfected (Y or N) N

Date Completed 9-20-93
Yield 20 (GPM)
Stabilized Water Level
Disinfectant Used

Total Depth of Well 225
Length of Test 2 hr
Natural Flow (Rate)
Amount Used

1 to 117
Material PVC
Schedule Sch 40

From _____ to _____
Size _____ Material _____
Weight/Schedule _____

From _____ to _____
Size _____ Material _____
Weight/Schedule _____

117 to 50

From _____ to _____

From _____ to _____

50 to 0
Hole Size 10
Neat
Method Pressure

From _____ to _____
Bore Hole Size _____
Type _____
Method _____

From _____ to _____
Bore Hole Size _____
Type _____
Method _____

Zones or Screened Intervals

185 to 205
Size _____ Diam. _____
to _____
Size _____ Diam. _____

From _____ to _____
Mesh Size _____ Diam. _____
From _____ to _____
Mesh Size _____ Diam. _____

From _____ to _____
Mesh Size _____ Diam. _____
From _____ to _____
Mesh Size _____ Diam. _____

* Use Data *

Well: Domestic X Agricultural _____ Industrial _____ Monitoring _____
Well: Community _____ Non Community _____

(Additional sheets if necessary)

Description of Formation or Sediment

Remarks

<p>0-107 107-117 117-185 185-205 205-225</p>	<p>Clay & Overburden Soft rock Soft brown rock Blue & white rock w/ voids - Water bearing Blue rock</p>	
--	---	--

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Drilling

Contractor Van's Construction Co., Inc.
 Address P.O. Box 3306
Fredericksburg, Va 22402
 Phone 703-373-7502

Drillers Signature *James Wilson* Date 10-1-93
 Representing Van's Construction Co. Inc.
 Virginia Contractors License Number ? 11-078610A