

State of Virginia
Water Well Completion Report

Drilling Corporation (Weadon Contractors)

P.O. Box 668

Maxton, N.C. 28364

Phone

Location Lot # 1 Long Branch Estates

Tax Map ID 27-18B-1

VDH Permit WS-93-7

WVCB Permit

WVCB ID

County Stafford

* Well Data *

General Information

Drilling Method Air rotary

Depth to Bedrock 43 ft

Static Water Level 40 ft

Well Disinfected (Y or N) N

Date Completed 12-14-95

Yield ± 1 (GPM)

Stabilized Water Level

Disinfectant Used

Total Depth of Well 505 ft

Length of Test 2 hr

Natural Flow (Rate)

Amount Used

Casing

From +1 to 63

Size 6 1/2" Material PVC

Weight/Schedule Sch 40

From to

Size Material

Weight/Schedule

From to

Size Material

Weight/Schedule

Gravel Pack

From to

From to

From to

Grout

From 63 to 0

Bore Hole Size 10"

Type Neat

Method Pressure

From to

Bore Hole Size

Type

Method

From to

Bore Hole Size

Type

Method

Water Zones or Screened Intervals

From 75 to 80

Mesh Size Diam.

From to

Mesh Size Diam.

From to

Mesh Size Diam.

From to

Mesh Size Diam.

From to

Mesh Size Diam.

From to

Mesh Size Diam.

* Use Data *

Private Well:

Domestic X

Agricultural

Industrial

Monitoring

Public Well:

Community

Non Community

Depth

Description of Formation of Well

Department of Health
Virginia
of Comp

<p>0-30 30-40 40-43 43-405</p>	<p>Clay Mica Gravel Rock</p>	<p>Light Brown/ Large/bro Hard granite w/voids</p>
--	--	--

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state laws regulations, ordinances and laws.

Drilling

Contractor VAN'S CONSTRUCTION CO., INC.
 Address P.O. BOX 3306
FREDERICKSBURG, VIRGINIA 22402
 Phone (703) 373-7502

Drillers Signature Bill Van Hay Date 12-14-95
 Representing VAN'S CONSTRUCTION CO., INC.
 Virginia Contractors License Number 2701.018610A