

Fax (703) 899 3702

(703) 373-7502

Commonwealth of Virginia Uniform Water Well Completion Report

Owner Mr. Richard Harris
 Address 3639 Sea Robin Drive
St. Petersburg FL 33705
 Phone 813 895-0318
 Location 13 Harris Lane

Tax Map ID 28-115B
 VDM Permt W-92-372
 VWCB Permit _____
 VWCB ID _____
 County Stafford
 Class III B

*** Well Data ***

General Information

Drilling Method Air Rotary
 Depth to Bedrock 57
 Static Water Level 50
 Well Disinfected (Y or N) N

Date Completed 11-19-92
 Yield 45 (GPM)
 Stabilized Water Level _____
 Disinfectant Used _____

Total Depth of Well 305'
 Length of Test 2 hours
 Natural Flow (Rate) _____
 Amount Used _____

Casing

From +1 to .67
 Size 6 1/2 Material PVC
 Weight/Schedule Sch. 40

From _____ to _____
 Size _____ Material _____
 Weight/Schedule _____

From _____ to _____
 Size _____ Material _____
 Weight/Schedule _____

Gravel Pack

From _____ to _____

From _____ to _____

From _____ to _____

Grout 11-17-92

From 50 to 0
 Bore Hole Size 11"
 Type Neat
 Method Pressure

From _____ to _____
 Bore Hole Size _____
 Type _____
 Method _____

From _____ to _____
 Bore Hole Size _____
 Type _____
 Method _____

Water Zones or Screened Intervals

From 100 to 105
 Mesh Size _____ Diam. _____
 From 235 to 240
 Mesh Size _____ Diam. _____

From 270 to 280
 Mesh Size _____ Diam. _____
 From 285 to 290
 Mesh Size _____ Diam. _____

From _____ to _____
 Mesh Size _____ Diam. _____
 From _____ to _____
 Mesh Size _____ Diam. _____

*** Use Data ***

Private Well: Domestic XX Agricultural _____ Industrial _____ Monitoring _____
 Public Well: Community _____ Non Community _____

(Use additional sheets if necessary)

Description of Formation or Sediment

Remarks

| | | |
|------------|--|-----------------|
| 0 - 20 | Sandy Brown Clay | |
| 20 - 40 | Brown Clay/Rock | |
| 40 - 67 | Decayed Soft Blue Rock | |
| 67 - 100 | Blue Granite | |
| *100 - 105 | Brown Shale | *Water Bearing |
| 105 - 160 | Blue Granite | |
| 160 - 165 | Red Shale | |
| *165 - 240 | Blue Granite w/voids | *Water Bearing |
| *240 - 305 | Blue Granite w/ Soft Voids and Shale Zones | * Water Bearing |

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Drilling

Contractor Van's Construction Co., Inc.
 Address P O Box 3306
Fredericksburg VA 22402
 Phone 703 373-7502

Drillers Signature Bill Van Hous Date 11-17-92
 Representing Van's Construction Co., Inc.
 Virginia Contractors License Number 2701018610