

**Commonwealth of Virginia
Uniform Water Well Completion Report**

Owner Rev. Ray J. Veison Tax Map ID 28-46A
 Address 68 Wood Road Bethel Baptist Church VDH Permit WS-94-34
Stafford 22554 1193 White Oak Rd VWCB Permit _____
 Phone 898-5580 Salmonville 22405 VWCB ID _____
 Location Mountain View Acres 46A 371-3650 County Stafford
627 -> Wood Road W. 1197 White Oak Rd 3/7/94
 Well Classification IIIA IIIB IIIC IV 3/9/94 Daniel J. Sartz
 * Well Data *

General Information
 Drilling Method Air Rotary Date Completed 5/26/94 Total Depth of Well 300'
 Depth to Bedrock 45 Yield 12 (GPM) Length of Test 1 Hr
 Static Water Level 30 Stabilized Water Level 180 Natural Flow (Rate) _____
 Well Disturbed (Y or N) _____ Disinfectant Used _____ Amount Used _____

Casing
 From #1 To 58 From _____ To _____ From _____ To _____
 Size 4 1/2 Material Steel Size _____ Material _____ Size _____ Material _____
 Weight/Schedule 188/1316 per ft Weight/Schedule _____ Weight/Schedule _____

Gravel Pack
 From _____ To _____ From _____ To _____ From _____ To _____
 Hole size 10" from 0 to 58 ft. 1/8" from 58 to 300 ft. _____ " from _____ to _____ ft.
 Grout _____ " from _____ to _____ ft.
 From 0 To 55 From _____ To _____ From _____ To _____
 Bore Hole Size 10" 3/4" Bore Hole Size _____ Bore Hole Size _____
 Type Bentonite Type _____ Type _____
 Method Pressure Grouting Method _____ Method _____

Water Zones or Screened Intervals
 From 160 To 161 From 220 To 221 From 280 To 281
 Mesh Size _____ Diam _____ Mesh Size _____ Diam _____ Mesh Size _____ Diam _____
 From _____ To _____ From _____ To _____ From _____ To _____
 Mesh Size _____ Diam _____ Mesh Size _____ Diam _____ Mesh Size _____ Diam _____

* Use Data *

Private Well: Domestic Agricultural _____ Industrial _____ Monitoring _____
 Public Well: Community _____ Non Community _____

* Abandonment Information *

Bored or Dug Wells	Wells other than Bored Wells
Casing Removed, Y or N?: _____	Casing removed, Y or N? _____
If Y, Depth to which casing was removed: _____	Depth to which casing was removed: _____
Depth and Type of Fill: _____	Applicable, depth(s), and type of gravel/sand fill: _____
Source of Fill _____	Source of gravel or sand: _____
Bentonite Plugs: From _____ to _____ From _____ to _____	Cement: From _____ to _____ From _____ to _____

Method of permanently marking location: _____
 Installed watertight top
 Suggest setting pump @ approx. 210 ft.

