

## Commonwealth of Virginia Uniform Water Well Completion Report

Owner Elmer C. Quinn  
 Address 137 Rockhill Church Road  
Stafford VA 22554  
 Phone 703 752-0107  
 Location Sunset Knoll Estates/

Tax Map ID WS-90-268  
35-91  
 VDH Permit \_\_\_\_\_  
 WVCB Permit \_\_\_\_\_  
 WVCB ID \_\_\_\_\_  
 County Stafford  
 " Class III-B

### • Well Data •

#### General Information

Drilling Method <u>Air Rotary</u>	Date Completed <u>8/28/92</u>	Total Depth of Well <u>205</u>
Depth to Bedrock <u>65</u>	Yield <u>25</u> (GPM)	Length of Test <u>2 hrs.</u>
Static Water Level <u>30</u>	Stabilized Water Level _____	Natural Flow (Rate) _____
Well Disinfected (Y or N) <u>y</u>	Disinfectant Used <u>Chlorine Tablets</u>	Amount Used <u>20 Tabs</u>

#### Casing

From <u>+1</u> to <u>75</u>	From _____ to _____	From _____ to _____
Size <u>6 1/2</u> Material <u>PVC</u>	Size _____ Material _____	Size _____ Material _____
Weight/Schedule <u>Sch. 40</u>	Weight/Schedule _____	Weight/Schedule _____

#### Gravel Pack

From _____ to _____	From _____ to _____	From _____ to _____
---------------------	---------------------	---------------------

#### Grout

From <u>60</u> to <u>0</u>	From _____ to _____	From _____ to _____
Bore Hole Size <u>10</u>	Bore Hole Size _____	Bore Hole Size _____
Type <u>Neat</u>	Type _____	Type _____
Method <u>Pressure</u>	Method _____	Method _____

#### Water Zones or Screened Intervals

From <u>75</u> to <u>145</u>	From <u>145</u> to <u>205</u>	From _____ to _____
Mesh Size _____ Diam. _____	Mesh Size _____ Diam. _____	Mesh Size _____ Diam. _____
From _____ to _____	From _____ to _____	From _____ to _____
Mesh Size _____ Diam. _____	Mesh Size _____ Diam. _____	Mesh Size _____ Diam. _____

### • Use Data •

Private Well:      Domestic xxx      Agricultural \_\_\_\_\_      Industrial \_\_\_\_\_      Monitoring \_\_\_\_\_  
 Public Well:      Community \_\_\_\_\_      Non Community \_\_\_\_\_

(Use additional sheets if necessary)

Section - P...  
Department of Health  
F.H.A. or V.A. Case Number  
If Applicable  
Date 2-1-93

Depth	Description of Formation or Sediment	Water Bearing
0 - 15	Clay	
15 - 65	Clay & Broken rock	
65 - 145	Red rock with voids	Water Bearing
145 - 205	Blue rock with voids	Water Bearing

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Drilling Contractor Van's Construction Co., Inc.  
 Address P O Box 3306  
Fred'bg VA 22402  
 Phone 703 373-7502

Drillers Signature *Carroll Wilson* Date 8-28-92  
 Representing Van's Construction Co., Inc.  
 Virginia Contractors License Number 2701018610