

**Commonwealth of Virginia  
Uniform Water Well Completion Report**

659-6119  
 Drilled to: Harry G. Beach / Robert Oliver  
 4337 Ridgemon Street / 103 Watersound Drive  
Fredricksburg, Va. 22405 / Stafford, Va. 22554  
 Phone \_\_\_\_\_ / 659-6119 Beacon  
 Location Beach Family Lot #2 / 312-3145 County Stafford  
 \*17 → L. on #724 → L. on Joshua Ct. → Left side of Cul de Sac  
 Well Classification IIIA / IIIB / IIIC / IV  
 Tax Map ID 35-68D-2  
 VDH Permit WS-91-116  
 WVCB Permit \_\_\_\_\_  
 WVCB ID \_\_\_\_\_  
 6/20/91 Mark Rudolph  
 6/23/91 T.T. Thompson

\* Well Data \*

**General Information**  
 Drilling Method Air Rotary Date Completed 2/11/93 Total Depth of Well 420'  
 Depth to Bedrock 110' Yield Approx 1.2 (GPM) Length of Test 1 HR.  
 Static Water Level 40 Stabilized Water Level 380' Natural Flow (Rate) \_\_\_\_\_  
 Well Disinfected (Y or N) \_\_\_\_\_ Disinfectant Used \_\_\_\_\_ Amount Used \_\_\_\_\_

**Casing**  
 From 1 To 84 From 84 To 124 From \_\_\_\_\_ To \_\_\_\_\_  
 Size 6 1/4 Material P.V.C. Size 6 1/4 Material P.V.C. Size \_\_\_\_\_ Material \_\_\_\_\_  
 Weight/Schedule SDR 27 Weight/Schedule SDR 21 Weight/Schedule \_\_\_\_\_

**Gravel Pack**  
 From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
 Hole size \_\_\_\_\_ Hole size 8 3/4" from 56 to 124 ft. Hole size 6" from 124 to 420 ft.  
 Grout From 0 To 50' From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
 Bore Hole Size 10" Bore Hole Size \_\_\_\_\_ Bore Hole Size \_\_\_\_\_  
 Type Bentonite Type \_\_\_\_\_ Type \_\_\_\_\_  
 Method Pressure Grouting Method \_\_\_\_\_ Method \_\_\_\_\_

**Water Zones or Screened Intervals**  
 From 130 To 131 From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_ Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_ Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_  
 From 380 To 381 From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_ Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_ Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_

\* Use Data \*

Private Well: Domestic  Agricultural \_\_\_\_\_ Industrial \_\_\_\_\_ Monitoring \_\_\_\_\_  
 Public Well: Community \_\_\_\_\_ Non Community \_\_\_\_\_

\* Abandonment Information \*

**Bored or Dug Wells**  
 Casing Removed, Y or N? \_\_\_\_\_  
 If Y, Depth to which casing was removed: \_\_\_\_\_  
 Depth and Type of Fill: \_\_\_\_\_  
 Source of Fill \_\_\_\_\_  
 Bentonite Plugs: From \_\_\_\_\_ to \_\_\_\_\_ From \_\_\_\_\_ to \_\_\_\_\_

**Wells other than Bored Wells**  
 Casing removed, Y or N? \_\_\_\_\_  
 Depth to which casing was removed: \_\_\_\_\_  
 Applicable, depth(s), and type of gravel/sand fill: \_\_\_\_\_  
 Source of gravel or sand: \_\_\_\_\_  
 Cement: From \_\_\_\_\_ to \_\_\_\_\_ From \_\_\_\_\_ to \_\_\_\_\_

Method of permanently marking location: \_\_\_\_\_  
 Installed watertight top  
 Suggest setting pump @ approx. 400 ft.

