Commonwealth of Virginia
Uniform Water Well Completion Report

Owner Ray Shackelford
Address 16 Ely Road
Hartwood, VA 22421
Phone
Location Rt 634

Tax Map ID 35-63-F 11
VDH Permit WS-93-4
VWCB Permit
VWCB ID
County Stafford

* Well Data *

General Information

Drilling Method Air Rotary
Depth to Bedrock 50
Static Water Level 50
Well Disinfected (Y or N) N

Date Completed 10-20-93
Yield 20 (GPM)
Stabilized Water Level
Disinfectant Used

Total Depth of Well 205
Length of Test 2 hr.
Natural Flow (Rate)
Amount Used

Casing

From +1 to 63
Size 6½ Material PVC
Weight/Schedule Sch 40

From to
Size Material
Weight/Schedule

From to
Size Material
Weight/Schedule

Gravel Pack

From 63 to 50

From to

From to

Grout

From 50 to 0
Bore Hole Size 10"
Type Neat
Method pressure

From to
Bore Hole Size
Type
Method

From to
Bore Hole Size
Type
Method

Water Zones or Screened Intervals

From 119 to 122
Mesh Size Diam.
From to
Mesh Size Diam.

From 190 to 195
Mesh Size Diam.
From to
Mesh Size Diam.

From 200 to 205
Mesh Size Diam.
From to
Mesh Size Diam.

* Use Data *

Private Well: Domestic X Agricultural Industrial Monitoring
Public Well: Community Non Community

(Use additional sheets if necessary)

Depth	Description of Formation or Sediment	Remarks
0-20	Overburden	
20-50	Mica	
50-62	Shale,grahite	
62-105	Granite	
105-119	Granite	
119-122	Granite - broken-soft - water bearing	
122-140	Granite	
140-205	Granite - with soft voids	

I certify that the information contained here is true and that this well was installed and constructed accordance with the permit and further that the well complies with all applicable state and loc regulations, ordinances and laws.

Drilling Contractor Van's Construction Co.,Inc.
Address P.o. Box 3306
Fredericksburg, Va. 22402
Phone (703) 373-7502

Drillers Signature Sam Redmon Date 10-26-93
Representing Van's Const. Co.,Inc.
Virginia Contractors License Number 2701 018610A