

# Commonwealth of Virginia Uniform Water Well Completion Report

Owner Helene Baron  
 Address 3812 Tall Oak Ct.  
Annandale VA 22003  
 Phone 703 256 4770  
 Location Lot 64C Firetrail Rt. 616

Tax Map ID 189-84-38-1  
36-64-c  
 VDH Permit \_\_\_\_\_  
 WVCB Permit \_\_\_\_\_  
 WVCB ID \_\_\_\_\_  
 County Stafford

### \* Well Data \*

#### General Information

Drilling Method Air Rotary  
 Depth to Bedrock 50  
 Static Water Level 30  
 Well Disinfected (Y or N) N

Date Completed 7/9/97  
 Yield 45 (GPM)  
 Stabilized Water Level \_\_\_\_\_  
 Disinfectant Used \_\_\_\_\_

Total Depth of Well 205'  
 Length of Test 2 hrs  
 Natural Flow (Rate) \_\_\_\_\_  
 Amount Used \_\_\_\_\_

#### Casing

From +1 to 59  
 Size 6 1/2 Material PVC  
 Weight/Schedule 40

From \_\_\_\_\_ to \_\_\_\_\_  
 Size \_\_\_\_\_ Material \_\_\_\_\_  
 Weight/Schedule \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Size \_\_\_\_\_ Material \_\_\_\_\_  
 Weight/Schedule \_\_\_\_\_

#### Gravel Pack

From \_\_\_\_\_ to \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_

#### Grout

From 50 to 0  
 Bore Hole Size 11"  
 Type Neat  
 Method pressure

From \_\_\_\_\_ to \_\_\_\_\_  
 Bore Hole Size \_\_\_\_\_  
 Type \_\_\_\_\_  
 Method \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Bore Hole Size \_\_\_\_\_  
 Type \_\_\_\_\_  
 Method \_\_\_\_\_

#### Water Zones or Screened Intervals

From 75 to 80  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From 100 to 105  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From 200 to 205  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

### \* Use Data \*

Private Well: Domestic x Agricultural \_\_\_\_\_ Industrial \_\_\_\_\_ Monitoring \_\_\_\_\_  
 Public Well: Community \_\_\_\_\_ Non Community \_\_\_\_\_

