

**COMMONWEALTH OF VIRGINIA
WATER WELL COMPLETION REPORT**

•BWCM No. _____

37A - 24

(Certification of Completion/County Permit)

Creston R. Noll
A & B Construction Co.
2 Woodrow Drive
Stafford, Va 22554
659-5366

SWCB Permit _____
County Permit _____
Certification of inspecting official _____
This well does _____ does not _____
meet code/low requirements.
S. _____
Date _____

General Board
Division St.
Va. 23230

County/City *Stafford*

County/City Stamp
Permit issued to
Joseph S. Rowe

• Virginia Plane Coordinates
N _____
E _____
Latitude & Longitude
N _____
W _____
• Topo. Map No. *183A*
• Elevation _____ ft.
• Formation _____
• Lithology _____
• River Basin _____
• Province _____
• Type Logs *D. L.*
• Cuttings *N. A.*
• Water Analysis _____
• Aquifer Test _____

• Owner _____
• Well Designation or Number _____
Address *9241 Edgemar Court Apt. 1*
Stafford Va 22
Phone *1-703-339*
• Drilling Contractor *John L. Danielson, Jr., Inc.*
Address *4616 Hood Drive*
Fredericksburg, Virginia 22401
Phone *(703) 898-6025*

For Office Use
SD-87-492 ¹⁶⁻¹⁻⁸⁷ *Ans Randolph*
Tax Map I.D. No. *37-42-24*
Subdivision *Abel Lake Forest*
Section _____
Block _____
Lot *#24*
Class Well I _____ IIA _____
IIB _____ IIA IIB _____
IIC _____ IID _____ IIF _____

WELL LOCATION: _____ (feet/miles) _____ (direction) of _____
and _____ (feet/miles) _____ (direction) of _____
(If possible please include map showing location marked) *(1 mile South of Intersecting #27 #251)*
(Off Lake Forest Drive)
Date started *2/19/88* • Date completed *2/23/88* Type rig *air rotary*

WELL DATA: New Reworked _____ Deepened _____
• Total depth _____ ft. *380*
• Depth to bedrock _____ ft. *52*
• Hole size (Also include reamed zones)
• *10* inches from _____ to *51* ft.
• *68* inches from *51* to *380* ft.
• _____ inches from _____ to _____ ft.
• Casing size (I.D.) and material
• *64* inches from *+1* to *51* ft.
Material *Steel*
Wt per foot *13.4* or wall thickness *.188* in.
• _____ inches from _____ to _____ ft.
Material _____
Wt per foot _____ or wall thickness _____ in.
340" • *4* inches from *40* to *380* ft. *Approx*
Material *P.V.C. Well Casing - Liner Slotted from 100' to*
Wt per foot _____ or wall thickness _____ in. *360"*
• Screen size and mesh for each zone (where applicable)
• _____ inches from _____ to _____ ft.
• Mesh size _____ Type _____
• _____ inches from _____ to _____ ft.
• Mesh size _____ Type _____
• _____ inches from _____ to _____ ft.
• Mesh size _____ Type _____
• _____ inches from _____ to _____ ft.
• Mesh size _____ Type _____
• Gravel pack
• From _____ to _____ ft.
• From _____ to _____ ft.
• Grout
• From *0* to *20* ft. Type *Neat Cement* *7/23/88*
• From _____ to _____ ft. Type _____

approximate drawdown *300* feet.
2. WATER DATA • Water temperature _____ °F
• Static water level (unpumped level measured) _____ ft. *60*
• Stabilized measured pumping water level _____ ft. *360*
• Stabilized yield *5* gpm after *1* hours
Natural Flow: Yes _____ No Flow rate _____ gpm
Comment on quality _____
3. WATER ZONES: From *150* To *151*
From *370* To *372* From _____ To _____
From _____ To _____ From _____ To _____
4. USE DATA:
Type of use Drinking Livestock Watering _____
Irrigation _____ Food processing _____ Household
Manufacturing _____ Fire safety _____ Cleaning _____
Recreation _____ Aesthetic _____ Cooling or heating _____
Injection _____ Other _____
• Type of facility Domestic Public water supply _____
Public institution _____ Farm _____ Industry _____
Commercial _____ Other _____
5. PUMP DATA: Type _____ • Rated HP _____
• Intake depth _____ • Capacity _____ at _____ head
6. WELLHEAD: Typt. well seal _____
Pressure tank _____ gal. Loc. _____
Sample tap _____ Measurement port _____
Well vent _____ Pressure relief valve _____
Gate valve _____ Check valve (when required) _____
Electrical disconnect switch on power supply _____
7. DISINFECTION: Well disinfected _____ yes _____ no _____
Date _____ Disinfectant used _____
Amount _____ Hours used _____
8. ABANDONMENT (where applicable) • yes _____ no _____
Casing pulled yes _____ no _____ not applicable _____
Plugging grout From _____ to _____ material _____
Pump installed through *A & B Construction*

Installed Watertight top
Suggest setting pump @ approx 360'
You will encounter liner @ approx 40 feet
Keep controllers & torque wrenches out of 4" liner.

