

Commonwealth of Virginia  
Uniform Water Well Completion Report

Owner WINFIELD ENTERPRISES  
Address 11201 BEAULACRES BLVD  
FRED, VA 22400  
Phone 371-4950  
Location RT. 617, MT ROSE CROUCH RD

Type Map ID 39-43A  
VOH-Permit SWP-97-185  
VWCB Permit \_\_\_\_\_  
VWCB ID \_\_\_\_\_  
County STAFFORD

\* Well Data \*

General Information

Drilling Method MUD ROTARY  
Depth to Bedrock N/A  
Static Water Level 60  
Well Disinfected (Y or N) Y

Date Completed 4-20-97  
Yield 43 (GPM)  
Stabilized Water Level 120  
Disinfectant Used CL-TAB

Total Depth of Well 231  
Length of Test 242  
Natural Flow (Rate) N  
Amount Used 20 TABS

Casing

From +1 to 250  
Size 4 1/2 Material PVC  
Weight/Schedule 40

From \_\_\_\_\_ to \_\_\_\_\_  
Size \_\_\_\_\_ Material \_\_\_\_\_  
Weight/Schedule \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Size \_\_\_\_\_ Material \_\_\_\_\_  
Weight/Schedule \_\_\_\_\_

Gravel Pack

From 250 to 50

From \_\_\_\_\_ to \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_

Grout

From 50 to 0  
Bore Hole Size B  
Type NEAT CEMENTS  
Method PRESSURE

From \_\_\_\_\_ to \_\_\_\_\_  
Bore Hole Size \_\_\_\_\_  
Type \_\_\_\_\_  
Method \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Bore Hole Size \_\_\_\_\_  
Type \_\_\_\_\_  
Method \_\_\_\_\_

Water Zones or Screened Intervals

From 230 to 250  
Mesh Size 20 Diam. 4 1/2  
From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

\* Use Data \*

Private Well: Domestic  Agricultural \_\_\_\_\_ Industrial \_\_\_\_\_ Monitoring \_\_\_\_\_  
Public Well: Community \_\_\_\_\_ Non Community \_\_\_\_\_

(Use additional sheets if necessary)

Depth	Description of Formation or Sediment	Remarks
0-5	CLAY	
5-100	SAND	
100-140	SAND CLAY	
140-200	SAND STONES	
200-230	Black Sand	
230-245	SAND - water Bearing	
245-260	CLAY	

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state laws regulations, ordinances and laws.

Drilling

Contractor VAN'S CONSTRUCTION CO., INC.

Address P.O. BOX 3306

FREDERICKSBURG, VIRGINIA 22402

Phone (703) 373-7502

Drillers Signature

*John Slater*

Date 11-21-97

Representing VAN'S CONSTRUCTION CO., INC.

Virginia Contractor License Number 2701.018610A