

# Commonwealth of Virginia Uniform Water Well Completion Report

Wesley, Jr. & Dora Whiting  
 Address 131 Porter Hill Road  
Stafford, VA 22554  
 Phone 371-3375  
 Location 131 Porter Hill Road

39-89-A

Tax Map ID \_\_\_\_\_  
 VDH Permit W-93-17  
 WVCB Permit \_\_\_\_\_  
 WVCB ID \_\_\_\_\_  
 County Stafford

### \* Well Data \*

#### General Information

Drilling Method Mud Rotary  
 Depth to Bedrock N/A  
 Static Water Level 100  
 Well Disinfected (Y or N) Y

Date Completed 3-17-93  
 Yield 25 (GPM)  
 Stabilized Water Level \_\_\_\_\_  
 Disinfectant Used Chlor Tab

Total Depth of Well 225  
 Length of Test 4  
 Natural Flow (Rate) \_\_\_\_\_  
 Amount Used 18

#### Casing

From +1 to 225  
 Size 4 1/2" Material PVC  
 Weight/Schedule Sch 40

From \_\_\_\_\_ to \_\_\_\_\_  
 Size \_\_\_\_\_ Material \_\_\_\_\_  
 Weight/Schedule \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Size \_\_\_\_\_ Material \_\_\_\_\_  
 Weight/Schedule \_\_\_\_\_

#### Gravel Pack

From 225 to 50

From \_\_\_\_\_ to \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_

#### Grout

From 50 to 0  
 Bore Hole Size 8"  
 Type Neat  
 Method Pressure

From \_\_\_\_\_ to \_\_\_\_\_  
 Bore Hole Size \_\_\_\_\_  
 Type \_\_\_\_\_  
 Method \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Bore Hole Size \_\_\_\_\_  
 Type \_\_\_\_\_  
 Method \_\_\_\_\_

#### Water Zones or Screened Intervals

From 195 to 215  
 Mesh Size 020 Diam. 4 1/2"  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

### \* Use Data \*

Private Well: Domestic  Agricultural \_\_\_\_\_ Industrial \_\_\_\_\_ Monitoring \_\_\_\_\_  
 Public Well: Community \_\_\_\_\_ Non Community \_\_\_\_\_

(Use additional sheets if necessary)

Depth

Description of Formation or Sediment

0 - 7	Clay, sandy	
7 - 28	Red Clay	
28 - 45	Sand Stone	
45 - 61	Clay	
61 - 70	Sand Stone	
70 - 94	Blue Clay	
94 - 105	Sand Stone	
105 - 195	Red-brown Clay	
195 - 215	Grey Sand *	*Water bea
215 - 225	Clay	

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

**Drilling**

**Contractor** Van's Const. Co., Inc.

**Address** P.O. Box 3306  
Fredericksburg, VA 22402

**Phone** 703-373-7502

**Drillers Signature** *John Slater* **Date** 3-17-93

**Representing** Van's Const., Co., Inc.

**Virginia Contractors License Number** 2701019610