


WATER WELL COMPLETION REPORT (Certificate of Completion)



Municipality
 Owner
 Well Designation of #
 Address

 Phone

PWS/ID #
 Tax Map ID #
 Subdivision
 Section/Block
 Lot/GPIN #
 Long/Lat
 Class/Well

Drilling Contractor Artesian Water Wells, Inc
 Address 11412 Gordon Road
 Fredericksburg, VA 22407
 Phone (540) 785-8163

Well Location: (feet/miles) (direction) of and
 feet/miles (direction) of
 (If possible please include map showing location marked)

Date Started Date Completed Type of Rig

1. Well Data:

New Rework Deepened

Total Depth ft
 Depth to Bedrock ft
 Hole size (Also include reamed zones)
 inches to ft
 inches to ft
 inches to ft

Gravel Pack
 Size From to ft
 Size From to ft
 Grout
 From to ft, Type
 From to ft, Type

Casing size (ID) and material
 inches to ft
 Material
 Wt. per ft or wall thickness in
 inches to ft
 Material
 Wt. per ft or wall thickness in
 inches to ft
 Material
 Wt. per ft or wall thickness in

2. Water Data: Water Temperature _____
 Static water level (unpumped level-measured) ft
 Stabilized measured pumping water level ft
 Stabilized yield gpm after hours
 Natural Flow: Yes No Flow rate gpm
 Comment on Quality

3. Water Zones: From To
 From To From To

4. Pump Data: Type Rated H.P.
 Intake depth Capacity at head
 Model No.

Screen size and mesh for each zone (where applicable)
 inches to ft
 Mesh size Type
 inches to ft
 Mesh size Type
 inches to ft
 Mesh size Type
 inches to ft
 Mesh size Type

5. Disinfection: Well disinfected? Yes No
 Date Disinfectant used
 Amount Hours used

6. Abandonment: Date Casing pulled?
 Chlorinated well (explain method)
 Plugging grout From to material

Log (Use Additional Sheets If Necessary)

Depth (Feet)		Type of Rock or Soil (Color, Material, Fossils, Hardness, Etc.)	Diagram of Well Construction	
From	To	Remarks (Water, Caving, Cavities, Broken, Core, Shot, Etc.)		
0	10	brown sandy clay	Not to Scale Press. Grout 83.5' - 0' 7" OD PVC + 1.5' - 83.5' 4.5" Casing 40' - 100' 4.5" Screen 100' - 140'	SCREEN WELL Water Tight Cap 10" Hole 0 - 83.5' 6.125" Hole 83.5' - 140'
10	35	tan sandy clay		
35	50	grey sandy clay		
50	110	hard grey green clay		
110	140	white sand		

8. Use Data

Type of use: Drinking Livestock Watering Irrigation Food Processing Household
 Manufacturing Fire Safety Cleaning Recreation Aesthetic Cooling or Heating
 Injection Other _____
 Type of Facility: Domestic Public Water Supply Public Institution Farm Industry
 Commercial Other _____

9. Wellhead: Type well seal

water tight cap Pressure Tank gal. Loc _____

Sample tap Measurement port Well Vent Pressure relief valve Gate valve
 Check valve (when required) _____ Electrical disconnect switch on power supply _____

10. Well lot dedicated? Size _____ ft. x _____ ft. Well house? Distance to nearest pollutant source _____
 Type _____ Distance to nearest property line _____ ft., Building _____ ft.

11. Water Service Pipe: Checked under _____ P.S.I. for _____ minutes. Pipe size _____ inches. Material _____
 Installer _____ Date _____

12. I certify that the information contained herein is true and correct and that this well has been installed and constructed in accordance with the requirements for well constructions specified in compliance with appropriate county or independent city ordinances and the laws and rules of the Commonwealth of Virginia.

Signature Wade N. [Signature] (Seal), Date 12/31/01 License No. 2705-046112
 (Well Driller or Authorized Person)