

Commonwealth of Virginia  
Uniform Water Well Completion Report

Owner LORNA SOLOMAN  
Address 18418 LORLAND TRL  
TRIANGLE VA 22172  
Phone 659-6499  
Location LOT 4 LITTLE TROUBLE SUB

Tax Map ID 40-BA-4  
VDH Permit SWP 97-158  
WVCB Permit \_\_\_\_\_  
WVCB ID \_\_\_\_\_  
County STAFFORD

\* Well Data \*

General Information

Drilling Method WIND ROTARY  
Depth to Bedrock N/A  
Static Water Level 50  
Well Disinfected (Y or N) Y

Date Completed 12-23-97  
Yield 15 (GPM)  
Stabilized Water Level \_\_\_\_\_  
Disinfectant Used TAP/CHLORINE

Total Depth of Well 210  
Length of Test 2 hr  
Natural Flow (Rate) N2  
Amount Used 20 TAPS

Casing

From +1 to 210  
Size 4 1/2 Material PVC  
Weight/Schedule 40

From \_\_\_\_\_ to \_\_\_\_\_  
Size \_\_\_\_\_ Material \_\_\_\_\_  
Weight/Schedule \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Size \_\_\_\_\_ Material \_\_\_\_\_  
Weight/Schedule \_\_\_\_\_

Gravel Pack

From 210 to 60

From \_\_\_\_\_ to \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_

Grout

From 60 to 0  
Bore Hole Size 8 1/2  
Type CEMENT/WATER  
Method PRESSURE

From \_\_\_\_\_ to \_\_\_\_\_  
Bore Hole Size \_\_\_\_\_  
Type \_\_\_\_\_  
Method \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Bore Hole Size \_\_\_\_\_  
Type \_\_\_\_\_  
Method \_\_\_\_\_

Water Zones or Screened Intervals

From 130 to 200  
Mesh Size 20 Diam. 4 1/2  
From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

\* Use Data \*

Private Well: \_\_\_\_\_  
Public Well: \_\_\_\_\_

Domestic Y  
Community \_\_\_\_\_

Agricultural \_\_\_\_\_  
Non Community \_\_\_\_\_

Industrial \_\_\_\_\_

Monitoring \_\_\_\_\_

(Use additional sheets if necessary)

Depth	Description of Formation or Sediment	Remarks
0-15	CLAY	
15-100	SANDY-CLAY	
100-130	CLAY (TIGHT BROWN)	
130-200	SAND / SANDSTONE	WATER BEARING
200-210	CLAY	

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state laws regulations, ordinances and laws.

Drilling

Contractor VAN'S CONSTRUCTION CO., INC.  
 Address P.O. BOX 3306  
FREDERICKSBURG, VIRGINIA 22402  
 Phone (703) 373-7502

Drillers Signature Bill Van Ar Date 1-29-98  
 Representing VAN'S CONSTRUCTION CO., INC.  
 Virginia Contractors License Number 2701.018610A