

COMMONWEALTH OF VIRGINIA
UNIFORM WATER WELL COMPLETION REPORT

OWNER: M.M. TIMMONS
ADDRESS: 1965 BROOKE RD.,
STAFFORD, VA 22554
PHONE: (540) 659-2671
LOCATION: ABOVE ADDRESS

TAX MAP ID#: 40-23
VDR PERMIT#: W-99-720
VWCB PERMIT:
VWCB ID:
COUNTY: **STAFFORD**

WELL CLASSIFICATION: IIIA: IIIB: XXXX IIIC IV

WELL DATA

GENERAL INFORMATION:

DRILLING METHOD: ROTARY	DATE COMPLETED: 05/03/00	TOT. DEPTH: 195 FT.
DEPTH TO BEDROCK:	YIELD: 30 (GPM)	TEST LENGTH: 4 HRS.
STATIC LEVEL: 30	STBLZED LEVEL: 55	NATURAL FLOW:
WELL DISINFECTED: YES	TYPE USED: CHLORINE	AMT. USED: 50 PPM

CASING:

FROM: +1 TO: 175	FROM: 175 TO: 185	FROM: TO:
SIZE: 4-1/2" MAT'L: PVC	SIZE: 2" MAT'L: GALV.	SIZE: MAT'L:
WEIGHT/SCHED: SDR 17	WEIGHT/SCHED: SDR 17	WEIGHT/SCHED:

GRAVEL PACK:

FROM	TO	FROM	TO	FROM	TO
------	----	------	----	------	----

GROUT:

FROM: 0 TO: 50	FROM: 50 TO: 175	FROM: 175 TO: 195
BORE HOLE SIZE: 8"	BORE HOLE SIZE: 7-1/4"	BORE HOLE SIZE: 3-7/8"
TYPE: BENSEAL	TYPE	TYPE
METHOD: PRESSURE	METHOD	METHOD

WATER ZONES:

FROM: 185 TO: 195	FROM	TO	FROM	TO
MESH: 15 DIAM: 2"	MESH	DIAM.	MESH	DIAM.

PRIVATE WELL: DOMESTIC: XXXX AGRICULTURAL INDUSTRIAL

. MONITORING

PUBLIC WELL: COMMUNITY NON-COMMUNITY

* DRILLERS LOG *

DEPTH	DESCRIPTION OF FORMATION OR SEDIMENT	REMARKS
0-20	SAND	
20-35	BLACK SAND	
35-155	GREEN AND BROWN CLAY	
155-175	SAND	
175-195	BLUE SAND	

I CERTIFY THAT THE INFORMATION CONTAINED HERE IS TRUE AND THAT THIS WELL WAS INSTALLED AND CONSTRUCTED IN ACCORDANCE WITH THE PERMIT AND FURTHER THAT THE WELL COMPLIES WITH ALL APPLICABLE STATE AND LOCAL REGULATIONS, ORDINANCES AND LAWS.

NAME KING GEORGE DRILLING SERVICE, INC.
ADDRESS 861 MACEDONIA LANE
COLONIAL BEACH, VA 22443
PHONE (804) 224-9130

DRILLER'S SIGNATURE *Charles E. Smith*
DATE: 05/03/2000 REPRESENTING CHARLES E. SMITH
VIRGINIA CONTRACTOR'S LICENSE NUMBER 2701 023065A