

Commonwealth of Virginia
Uniform Water Well Completion Report

43-198

Owner Paul Parkey
Address 3 Artillery Dr
Fredericksburg, VA 22406
Phone 752-5913
Location RT 654 - Rocky Run Road

Tax Map ID 43-1818
VDH Permit SWP-96-68
WVCB Permit _____
WVCB ID _____
County Stafford

* Well Data *

General Information

Drilling Method Air rotary Date Completed 9-4-96 Total Depth of Well 365'
Depth to Bedrock 40' Yield 5 (GPM) Length of Test 2 hr
Static Water Level 40' Stabilized Water Level _____ Natural Flow (Rate) _____
Well Disinfected (Y or N) N Disinfectant Used _____ Amount Used _____

Casing

From +1 To 52 From _____ To _____ From _____ To _____
Size 6 1/4" Material pvc Size _____ Material _____ Size _____ Material _____
Weight/Schedule Sch 40 Weight/Schedule _____ Weight/Schedule _____

Gravel Pack

From _____ To _____ From _____ To _____ From _____ To _____

Grout

From 52 To 0 From _____ To _____ From _____ To _____
Bore Hole Size 1 1/2" Bore Hole Size _____ Bore Hole Size _____
Type Neat Type _____ Type _____
Method Pressure Method _____ Method _____

Water Zones or Screened Intervals

80-85
From 180 To 185 From 230 To 235 From 355 To 360
Mesh Size _____ Diam _____ Mesh Size _____ Diam _____ Mesh Size _____ Diam _____
From _____ To _____ From _____ To _____ From _____ To _____
Mesh Size _____ Diam _____ Mesh Size _____ Diam _____ Mesh Size _____ Diam _____

* Use Data *

Private Well: Domestic X Agricultural _____ Industrial _____ Monitoring _____
Public Well: Community _____ Non Community _____

* Abandonment Information *

Bored or Dug Wells

Casing Removed, Y or N?: _____
If Y, Depth to which casing was removed: _____
Depth and Type of Fill: _____
Source of Fill: _____
Bentonite Plugs: From _____ to _____ From _____ to _____

Wells other than Bored Wells

Casing removed, Y or N? _____
Depth to which casing was removed: _____
Applicable, depth(s), and type of gravel/sand fill: _____
Source of gravel or sand: _____
Cement: From _____ to _____ From _____ to _____

Method of permanently marking location: _____

* Drillers Log *

Depth	Description of Formation or Sediment	Remarks
0-40	Clay	Brown
40-52	Rock	Brown shale
52-365	Rock	Soft granite brown shale w/ voids



(User additional Sheets if necessary)

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Name VAN'S CONSTRUCTION CO., INC.

Address PO BOX 3306

FREDERICKSBURG, VA 22402

Phone (540) 373-7502

Drillers Signature Bill Van Hoy

Date 9.4.96 Representing VAN'S CONSTRUCTION CO., INC.

Virginia Contractors License Number 2701-018610A