

**Commonwealth of Virginia  
Uniform Water Well Completion Report**

Owner John M. Jones  
 Address 8701 Zachary Taylor Hwy  
Unionville Va. 22567  
 Phone 703-854-4673  
 Location \_\_\_\_\_

Tax Map ID 430-1-2  
 VDH Permit \_\_\_\_\_  
 VWCB Permit \_\_\_\_\_  
 VWCB ID \_\_\_\_\_  
 County Stafford County  
Class III B

\* Well Data \*

**General Information**  
 Drilling Method Rotary  
 Depth to Bedrock 90'  
 Static Water Level 28  
 Well Disinfected (Y or N) Yes

Date Completed 5/1/93  
 Yield 3 (GPM)  
 Stabilized Water Level \_\_\_\_\_  
 Disinfectant Used NDA

Total Depth of Well 415  
 Length of Test 2 hours  
 Natural Flow (Rate) \_\_\_\_\_  
 Amount Used 1 pt.

**Casing**  
 From 0 to 106  
 Size 6 1/4 Material Steel  
 Weight/Schedule 13.75 100000

From \_\_\_\_\_ to \_\_\_\_\_  
 Size \_\_\_\_\_ Material \_\_\_\_\_  
 Weight/Schedule \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Size \_\_\_\_\_ Material \_\_\_\_\_  
 Weight/Schedule \_\_\_\_\_

**Gravel Pack**  
 From \_\_\_\_\_ to \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_

**Grout**  
 From 0 to 106  
 Bore Hole Size 10" 0-106  
 Type \_\_\_\_\_  
 Method concrete

From \_\_\_\_\_ to \_\_\_\_\_  
 Bore Hole Size 6" from 106 to 415'  
 Type \_\_\_\_\_  
 Method \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Bore Hole Size \_\_\_\_\_  
 Type \_\_\_\_\_  
 Method \_\_\_\_\_

**Water Zones or Screened Intervals**  
 From 130 to 135  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From 275 to 380  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
 From \_\_\_\_\_ to \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

\* Use Data \*

Private Well: Domestic  Agricultural \_\_\_\_\_ Industrial \_\_\_\_\_ Monitoring \_\_\_\_\_  
 Public Well: Community \_\_\_\_\_ Non Community \_\_\_\_\_

**Drillers Log \***  
(Use additional sheets if necessary)

SIDBERT W. ...  
150 C OLDE GREENWICH DRIVE

Depth	Description of Formation or Sediment	Remarks
0-90 90-415	over burden rock	

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Drilling Contractor W. J. ... Drilling Co., Inc.  
P.O. Box 325  
Keeneland, Va 22784

Phone 439-3030

Drillers Sig: H. L. ... Date 5/5/13

Representing \_\_\_\_\_

Virginia Contractors License Num. 2705-020358