

Spick/Low
New Century Development
P.O. Box 152
Stafford, Va. 22554
659-1564

Commonwealth of Virginia
Uniform Water Well Completion Report

Owner Mr. Krowder
Address _____

Tax Map ID 43C-1-1
VDH Permit WS-13-105
WVCB Permit _____
WVCB ID _____

Phone 659-3221
Location Holly Cross Estates Sub 1 Lot 1 (Holly Berry Road)
(655)

County Stafford
5/4/93 Daniel J. Gandy

Well Classification IIIA _____ IIIB IIIC _____ IV _____
* Well Data *

SFF

General Information
Drilling Method Air Rotary
Depth to Bedrock 55
Static Water Level 40
Well Disinfected (Y or N) _____

Date Completed 10/20/93
Yield 12 (GPM)
Stabilized Water Level 340
Disinfectant Used _____

Total Depth of Well 380
Length of Test 1 HR.
Natural Flow (Rate) _____
Amount Used _____

Casing
From 71 To 65
Size 6 7/8 Material PVC
Weight/Schedule SDR 29

From _____ To _____
Size _____ Material _____
Weight/Schedule _____

From _____ To _____
Size _____ Material _____
Weight/Schedule _____

Gravel Pack
From _____ To _____

From _____ To _____

From _____ To _____

Hole size
10" from 0 to 55 ft.

7 7/8" from 55 to 65 ft.

6 7/8" from 65 to 380 ft.

Grout
From 0 To 50+
Bore Hole Size 10" 10 1/2"
Type Bentonite
Method Pressure Grouting

From _____ To _____
Bore Hole Size _____
Type _____
Method _____

From _____ To _____
Bore Hole Size _____
Type _____
Method _____

Water Zones or Screened Intervals
From 80 To 81
Mesh Size _____ Diam _____
From _____ To _____
Mesh Size _____ Diam _____

From _____ To _____
Mesh Size _____ Diam _____
From _____ To _____
Mesh Size _____ Diam _____

From _____ To _____
Mesh Size _____ Diam _____
From _____ To _____
Mesh Size _____ Diam _____

* Use Data *

Private Well: Domestic Agricultural _____ Industrial _____ Monitoring _____
Public Well: Community _____ Non Community _____

* Abandonment Information *

Bored or Dug Wells
Casing Removed, Y or N?: _____
If Y, Depth to which casing was removed: _____
Depth and Type of Fill: _____
Source of Fill: _____
Bentonite Plugs: From _____ to _____ From _____ to _____

Wells other than Bored Wells
Casing removed, Y or N? _____
Depth to which casing was removed: _____
Applicable, depth(s), and type of gravel/sand fill: _____
Source of gravel or sand: _____
Cement: From _____ to _____ From _____ to _____

Method of permanently marking location: _____
 Installed watertight top
Suggest setting pump @ approx. 340 ft.

