

40174 11711
Fried
Stafford

Commonwealth of Virginia Uniform Water Well Completion Report

Owner Regentius Court
Address 1703 Main Street
Charlottesville VA 22901
Phone _____
Location _____

Tax Map ID 44-89 A
VDH Permit 5-0-98-263
VWCS Permit _____
VWCS ID _____
County Stafford

• Well Data •

General Information
Drilling Method Rotary
Depth to Bedrock 55
Static Water Level 49
Well Disinfected (Y or N) Y

Date Completed 3/4/99
Yield 12
Sanitized Water Level _____
Disinfectant Used _____

Total Depth of Well 225
Length of Test 30 min
Natural Flow (Rate) _____
Amount Used _____

Casing
From 65' To 0'
Size 1 1/2" Material PVC
Weight/Schedule See #1

From _____ To _____
Size _____ Material _____
Weight/Schedule _____

From _____ To _____
Size _____ Material _____
Weight/Schedule _____

Gravel Pack
From 9 1/4' To _____

From _____ To _____

From _____ To _____

Grout
From 55' To 0'
Bore Hole Size 1 1/2"
Type Portland / Sand
Method Grout

From _____ To _____
Bore Hole Size _____
Type _____
Method _____

From _____ To _____
Bore Hole Size _____
Type _____
Method _____

Water Zones or Screened Intervals
From 145' To 150'
Mesh Size _____ Diam _____
From 180' To 185'
Mesh Size _____ Diam _____

From _____ To _____
Mesh Size _____ Diam _____
From _____ To _____
Mesh Size _____ Diam _____

From _____ To _____
Mesh Size _____ Diam _____
From _____ To _____
Mesh Size _____ Diam _____

• Use Data •

Private Well: Domestic Agricultural _____ Industrial _____ Monitoring _____
Public Well: Community _____ Non Community

• Abandonment Information •

Sealed or Dry Wells
Casing Removed, Y or N? _____
If Y, Depth to which casing was removed: _____
Depth and Type of PB: _____
Source of PB: _____
Bentonite Plug: From _____ to _____ From _____ to _____

Wells other than Sealed Wells
Casing removed, Y or N? _____
Depth to which casing was removed: _____
Applicable, depth(s), and type of gravel/sand fill: _____
Source of gravel or sand: _____
Gravel: From _____ to _____ From _____ to _____

Method of permanently marking location: _____

44-89 A

SWP-98-283

• Drillers Log •

Depth	Description of Formation or Sediment	Remarks
0' to 15'	Brown Soil	
15' to 30'	Light Brown Sand	
30' to 40'	yellow sand	
0' to 55'	white sand	
5' to 225'	Granite/Quartz	
	water level fair	

(Use additional sheets if necessary)

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Name DIAMOND WELL DRILLING
 Address 18290 Edwards Shop Road
ELWOOD, VIRGINIA 22718
 Phone (800) 399-1810

Drillers Signature James H. Hester, Jr.
 Date 3/7/99

Virginia Contractors License Number _____