

Commonwealth of Virginia
 Uniform Water Well Completion Report

Owner Lawton Mussleman Tax Map ID 49-39-16
 Address 430 Woodloring Rd. VIII Permit WS-92-210
Stafford, VA VWCB Permit _____
 Phone 373-5949 VWCB ID _____
 Location c. 218 to 600 to 712 (Sparrows Subd. 6/16) County Stafford
 Well Classification IIIA _____ IIIB _____ IIIC _____ IV _____

* Well Data *

General Information
 Drilling Method Rotary Date Completed 11-30-95 Total Depth of Well 176 FT.
 Depth to Bedrock _____ Yield 60 (GPM) Length of Test 4 hrs.
 Static Water Level 30 Stabilized Water Level 60 Natural Flow (rate) _____
 Well Disinfected (Y/N) Y Disinfectant Used Chlorine Amount Used 50 PPM

Casing
 From 7 to 160 From 156 to 166 From _____ to _____
 Size 4 1/2" Material PVC Size 2" Material Galv. Size _____ Material _____
 Weight/Schedule 40 Weight/Schedule 40 Weight/Schedule _____

Gravel Pack
 From _____ to _____ From _____ to _____ From _____ to _____

Grout
 From 7 to 50 From 50 to 160 From 160 to 176
 Bore Hole Size 8" Bore Hole Size 7" Bore Hole Size 3 7/8"
 Type Grout Type _____ Type _____
 Method Pressure Method _____ Method _____

Water Zones or Screened Intervals
 From 160 to 176 From _____ to _____ From _____ to _____
 Mesh Size 15 Diam. 2" Mesh Size _____ Diam. _____ Mesh Size _____ Diam. _____
 From _____ to _____ From _____ to _____ From _____ to _____
 Mesh Size _____ Diam. _____ Mesh Size _____ Diam. _____ Mesh Size _____ Diam. _____

* Use Data *

Private well: Domestic Agricultural _____ Industrial _____ Monitoring _____
 Public Well: Community _____ Non Community _____

* Abandonment Information *

Bored or Aug Wells	Wells other than Bored Wells
Casing Removed, Y or N? _____	Casing Removed, Y or N? _____
If Y, Depth Removed: _____	If Y, Depth Removed: _____
Depth and Type of Fill: _____	Depth and type of Fill: _____
Source of Fill: _____	Source of Gravel or Sand: _____
Bentonite Plugs: From _____ to _____	Cement: From _____ to _____
From _____ to _____	From _____ to _____

Method of permanently marking location: _____

DRILLERS LOG

DEPTH	DESCRIPTION OF FORMATION OR SEDIMENT	REMARKS
0 - 20'	1" clay	<p>well cap 12" above ground 50' grout 4 1/2" PVC Rubber packer 2" steel 10' screen ground level static head</p>
20 - 150'	sand	
50 - 160'	clay	
176'	sand	

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Company Name King George Drilling
Address Box 88K
Colonial Beach, VA 22443
Phone (404) 224-9130

Driller's Signature [Signature]
Date 11-21-77 Representing Kenneth M. Frack, Jr.

Virginia Contractors License Number 023065A