

**Commonwealth of Virginia  
Uniform Water Well Completion Report**

Owner Ralph C. Meina, Barbara Meina, Stephen H. Meina, Ralph C. Meina III  
 Address 5018 Washington Drive Bethesda, Md. 20816  
 Phone 1-301-229-2067  
 Location Marlborough Hunt #621 - Lot # left just before Atomic Overlook  
 Well Classification IIIA IIIB  IIIC IV  
 \* Well Data \*

Tax Map ID 49-15  
 VDH Permit W5-94-51  
 VWCB Permit \_\_\_\_\_  
 VWCB ID \_\_\_\_\_  
 County Stafford  
3/1/94 Original Installation  
3/4/94 3rd Reinstall  
SFF

**General Information**

Drilling Method Air Rotary Date Completed 7/28/95 Total Depth of Well 300'  
 Depth to Bedrock \_\_\_\_\_ Yield 25 (GPM) Length of Test approx 1 Hr.  
 Static Water Level approx 100' Stabilized Water Level 220' Natural Flow (Rate) \_\_\_\_\_  
 Well Disinfected (Y or N) \_\_\_\_\_ Disinfectant Used \_\_\_\_\_ Amount Used \_\_\_\_\_

**Casing**

From <u>11'</u> To <u>70'</u>	From <u>65'</u> To <u>260'</u>	From <u>280'</u> To <u>300'</u>
Size <u>6 1/2"</u> Material <u>P.V.C.</u>	Size <u>4"</u> Material <u>P.V.C.</u>	Size <u>4"</u> Material <u>P.V.C.</u>
Weight/Schedule <u>SDR 27</u>	Weight/Schedule <u>Sch 40</u>	Weight/Schedule <u>Sch 40</u>

**Gravel Pack**

From _____ To _____	From _____ To _____	From _____ To _____
Hole size <u>10" from 0 to 50ft.</u>	<u>7 7/8" from 50 to 70 ft.</u>	<u>6" from 70' to 300ft.</u>

Grout From <u>0</u> To <u>50+ 8 1/2'</u>	From _____ To _____	From _____ To _____
Bore Hole Size <u>10"</u>	Bore Hole Size _____	Bore Hole Size _____
Type <u>Bentonite</u>	Type _____	Type _____
Method <u>Pressure Grouting</u>	Method _____	Method _____

**Water Zones or Screened Intervals**

From <u>260</u> To <u>280</u>	From <u>210</u> To <u>285</u>	From _____ To _____
Mesh Size <u>.020</u> Diam <u>4" (P.V.C.)</u>	Mesh Size _____ Diam _____	Mesh Size _____ Diam _____
From _____ To _____	From _____ To _____	From _____ To _____
Mesh Size _____ Diam _____	Mesh Size _____ Diam _____	Mesh Size _____ Diam _____

**\* Use Data \***

Private Well: Domestic  Agricultural \_\_\_\_\_ Industrial \_\_\_\_\_ Monitoring \_\_\_\_\_  
 Public Well: Community \_\_\_\_\_ Non Community \_\_\_\_\_

3/4 HP 7 GPM Red Jacket  
Submersible Pump  
Serial # 0486667  
Pump #  
Motor # 0486666

**\* Abandonment Information \***

<b>Bored or Dug Wells</b>	<b>Wells other than Bored Wells</b>
Casing Removed, Y or N? _____	Casing removed, Y or N? _____
If Y, Depth to which casing was removed: _____	Depth to which casing was removed: _____
Depth and Type of Fill: _____	Applicable, depth(s), and type of gravel/sand fill: _____
Source of Fill _____	Source of gravel or sand: _____
Bentonite Plugs: From _____ to _____ From _____ to _____	Cement: From _____ to _____ From _____ to _____

WX 250  
Frost Proof by draft

**Method of permanently marking location:**

Installed watertight top  
 Suggest setting pump @ approx. 240 ft.  
- Casing will telescope to 4" @ approx 65'  
- Suggest keeping torque arrestors & centralizers out of 4" casing

