

COMMONWEALTH OF VIRGINIA
UNIFORM WATER WELL COMPLETION REPORT

OWNER: DOUGLAS MORGAN
ADDRESS: 4 WOODBERRY COURT
FREDERICKSBURG, VA 22405
PHONE: (540) 371-5613
LOCATION: 40 MCCAULEY LANE

TAX MAP ID#: 55-194-B
PERMIT#: SWP-00-346
WCB PERMIT:
VWCB ID:
COUNTY: STAFFORD

WELL CLASSIFICATION: IIIA: IIIB: XXXX IIIC: IV:

"WELL DATA"

GENERAL INFORMATION:

DRILLING METHOD: ROTARY	DATE COMPLETED: 03/15/01	TOT. DEPTH: 207 FT.
DEPTH TO BEDROCK:	YIELD: 20 (GPM)	TEST LENGTH: 4 HRS.
STATIC LEVEL: 100	STBLZED LEVEL: 130	NATURAL FLOW:
WELL DISINFECTED: YES	TYPE USED: CHLORINE	AMT. USED: 50 PPM

CASING:

FROM: +1 TO: 198	FROM: 187 TO: 197	FROM: TO:
SIZE: 4.5" MAT'L: PVC	SIZE: 2" MAT'L: GLV.	SIZE: 2" MAT'L: GLV.
WEIGHT/SCHED: SDR 17	WEIGHT/SCHED: SCH. 40	WEIGHT/SCHED: SCH. 40

GRAVEL PACK:

FROM	TO	FROM	TO	FROM	TO
------	----	------	----	------	----

GROUT:

FROM: 0 TO: 50	FROM: 50 TO: 198	FROM: 198 TO: 207
BORE HOLE SIZE: 8"	BORE HOLE SIZE: 7-1/4"	BORE HOLE SIZE: 3-7/8"
TYPE: BENSEAL	TYPE:	TYPE:
METHOD: PRESSURE	METHOD:	METHOD:

WATER ZONES:

FROM: 197 TO: 207	FROM: TO:	FROM: TO:
MESH: 15 DIAM.: 2"	MESH: DIAM.:	MESH: DIAM.:

PRIVATE WELL: DOMESTIC: XXXX AGRICULTURAL INDUSTRIAL

MONITORING

PUBLIC WELL: COMMUNITY NON-COMMUNITY

Diagram of well number: 30213

, = Casing () = Hole - - = Screen ! ! = Perforation

FORMATION DESCRIPTION	DEPTH	COMMENTS
	+1	Surface
BROWN SAND AND CLAY	35	
GREEN CLAY	55	
GRAY AND BLACK SAND	75	
GRAY CLAY	100	Static Level
BLACK SAND AND SHELLS	198	
WHITE SAND	207	Completion
	207	Drilled To