

**Commonwealth of Virginia  
Uniform Water Well Completion Report**

Owner Charles R. Stone Jr.  
 Address 47 Hayward Lane  
Fredericksburg, Va. 22405  
 Phone 373-0364  
 Location Charles R. Stone Family Sub. #1  
218 R.O. 603 - Hayward Lane

Tax Map ID 55-224G (Part)  
 VDH Permit SNP-95-88  
 VWCB Permit \_\_\_\_\_  
 VWCB ID \_\_\_\_\_  
 County STAFFORD  
6/10/96 Daniel J. Juchyn  
C.R.G.

Well Classification IIIA IIIB IIIC IV  
 \* Well Data \*

**General Information**

Drilling Method Mud Rotary  
 Depth to Bedrock \_\_\_\_\_  
 Static Water Level 100'  
 Well Disinfected (Y or N) \_\_\_\_\_

Date Completed 8/18/97  
 Yield 30 (GPM)  
 Stabilized Water Level 160'  
 Disinfectant Used \_\_\_\_\_

Total Depth of Well 237  
 Length of Test approx 7 hrs  
 Natural Flow (Rate) \_\_\_\_\_  
 Amount Used \_\_\_\_\_

**Casing**

From #1 To 200  
 Size 4 1/2 Material P.V.C.  
 Weight/Schedule S.D.R. 17

From 220 To 227  
 Size 4 1/2 Material P.V.C.  
 Weight/Schedule S.D.R. 17

From \_\_\_\_\_ To \_\_\_\_\_  
 Size \_\_\_\_\_ Material \_\_\_\_\_  
 Weight/Schedule \_\_\_\_\_

**Gravel Pack**

From 50 To 227

From \_\_\_\_\_ To \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_

**Hole size**

7 7/8 from 0 to 227 ft.

\_\_\_\_\_ " from \_\_\_\_\_ to \_\_\_\_\_ ft.

\_\_\_\_\_ " from \_\_\_\_\_ to \_\_\_\_\_ ft.

**Grout**

From 0 To 50'  
 Bore Hole Size 7 7/8  
 Type Bentonite  
 Method Pressure Grouting

From \_\_\_\_\_ To \_\_\_\_\_  
 Bore Hole Size \_\_\_\_\_  
 Type \_\_\_\_\_  
 Method \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_  
 Bore Hole Size \_\_\_\_\_  
 Type \_\_\_\_\_  
 Method \_\_\_\_\_

**Water Zones or Screened Intervals**

From 200 To 220  
 Mesh Size .020 Diam 4 1/2" (P.V.C.)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_

approx water zone  
 From 200 To 220  
 Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Mesh Size \_\_\_\_\_ Diam \_\_\_\_\_

**\* Use Data \***

Private Well: Domestic  Agricultural \_\_\_\_\_ Industrial \_\_\_\_\_ Monitoring \_\_\_\_\_  
 Public Well: Community \_\_\_\_\_ Non Community \_\_\_\_\_

**\* Abandonment Information \***

**Bored or Dug Wells**

Casing Removed, Y or N?: \_\_\_\_\_  
 If Y, Depth to which casing was removed: \_\_\_\_\_  
 Depth and Type of Fill: \_\_\_\_\_  
 Source of Fill \_\_\_\_\_  
 Bentonite Plugs: From \_\_\_\_\_ to \_\_\_\_\_ From \_\_\_\_\_ to \_\_\_\_\_

**Wells other than Bored Wells**

Casing removed, Y or N? \_\_\_\_\_  
 Depth to which casing was removed: \_\_\_\_\_  
 Applicable, depth(s), and type of gravel/sand fill: \_\_\_\_\_  
 Source of gravel or sand: \_\_\_\_\_  
 Cement: From \_\_\_\_\_ to \_\_\_\_\_ From \_\_\_\_\_ to \_\_\_\_\_

**Method of permanently marking location:**

Installed watertight top  
 Suggest setting pump @ approx. 180 ft.

