

Commonwealth of Virginia Uniform Water Well Completion Report

Owner BARBARA TETU
 Address 179 Salvington Rd
Falmouth, VA 22405
 Phone 373-4550
 Location RF 603

Tax Map ID 56-322 Part
 VDH Permit SWP95 85
 WWCB Permit _____
 WWCB ID _____
 County Stafford

* Well Data *

General Information
 Drilling Method Mud rotary Date Completed 2-24-97
 Depth to Bedrock N/A Yield 30 (GPM)
 Static Water Level 100 Stabilized Water Level _____
 Well Disinfected (Y or N) Y Disinfectant Used Gran chlor

Total Depth of Well 235
 Length of Test _____
 Natural Flow (Rate) _____
 Amount Used 1 cup

Casing
 From +1 to 234
 Size 4 1/2" Material PVC
 Weight/Schedule SCH 40

From _____ to _____
 Size _____ Material _____
 Weight/Schedule _____

From _____ to _____
 Size _____ Material _____
 Weight/Schedule _____

Gravel Pack
 From 234 to 50

From _____ to _____

From _____ to _____

Grout 50 to 0
 From _____ to _____
 Bore Hole Size 8"
 Type Neat
 Method Pressure

From _____ to _____
 Bore Hole Size _____
 Type _____
 Method _____

From _____ to _____
 Bore Hole Size _____
 Type _____
 Method _____

Water Zones or Screened Intervals
 From 210 to 230
 Mesh Size 20 Diam. 4 1/2"
 From 210 to 230
 Mesh Size _____ Diam. _____

From _____ to _____
 Mesh Size _____ Diam. _____
 From _____ to _____
 Mesh Size _____ Diam. _____

From _____ to _____
 Mesh Size _____ Diam. _____
 From _____ to _____
 Mesh Size _____ Diam. _____

* Use Data *

Private Well: Domestic X Agricultural _____ Industrial _____ Monitoring _____
 Public Well: Community _____ Non Community _____

Drillers Log *
(Use additional sheets if necessary)

Depth	Description of Formation or Soilment	Remarks
0-20	Sand	
20-75	Clay	
75-115	Shells	
115-200	Black sand	
200-210	Clay	
210-230	Grey sand	Water-Bearing
230-235	Clay	

I certify that the information contained here is true and that this well was installed and constructed in accordance with the permit and further that the well complies with all applicable state and local regulations, ordinances and laws.

Drilling Contractor VAN'S CONST. CO., INC.

Address P.O. Box 3306

Fredericksburg, VA 22402

Phone 373-7502

Drillers Signature *John Slater* Date 2-24-97

Representing Van's Const. Co., Inc.

Virginia Contractors License Number 2701-018610A