

VAN'S CONSTRUCTION CO., INC.

703 899 3702

P. 3

Commonwealth of Virginia  
Uniform Water Well Completion Report

59-40-42A

59-40-42A

Owner PAUL SHELTON  
Address 64 Muddy Creek Lane  
Fredericksburg, VA 22405  
Phone 371-0970  
Location McGATLY Road

Tax Map ID \_\_\_\_\_  
VDH Permit WS-93-142  
WVCS Permit \_\_\_\_\_  
WVCS ID \_\_\_\_\_  
County Stafford

Well Data

General Information

Drilling Method Mud ROTARY  
Depth to Bedrock N/A  
Static Water Level 100  
Disinfected (Y or N) Y

Date Completed 9-16-93  
Yield 25 (GPM)  
Stabilized Water Level \_\_\_\_\_  
Disinfectant Used Gran chlor

Total Depth of Well 235  
Length of Test 3  
Natural Flow (Rate) \_\_\_\_\_  
Amount Used 2 cups

Casing  
From 0 to 235  
Material PVC  
Weight/Schedule Sch 40

From \_\_\_\_\_ to \_\_\_\_\_  
Size \_\_\_\_\_ Material \_\_\_\_\_  
Weight/Schedule \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Size \_\_\_\_\_ Material \_\_\_\_\_  
Weight/Schedule \_\_\_\_\_

Gravel Pack  
From 230 to 50

From \_\_\_\_\_ to \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_

Flow  
From 50 to 0  
Bore Hole Size 7  
Type Neat  
Method Pressure

From \_\_\_\_\_ to \_\_\_\_\_  
Bore Hole Size \_\_\_\_\_  
Type \_\_\_\_\_  
Method \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Bore Hole Size \_\_\_\_\_  
Type \_\_\_\_\_  
Method \_\_\_\_\_

Water Zones or Screened Intervals  
From 195 to 215  
Mesh Size 0.20 Diam. 45  
From 195 to 215  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_  
From \_\_\_\_\_ to \_\_\_\_\_  
Mesh Size \_\_\_\_\_ Diam. \_\_\_\_\_

Use Data

Private Well \_\_\_\_\_ Domestic X Agricultural \_\_\_\_\_ Industrial \_\_\_\_\_ Monitoring \_\_\_\_\_  
Public Well \_\_\_\_\_ Community \_\_\_\_\_ Non Community \_\_\_\_\_

| Depth  | Description of Formation or Sediment | Remarks |
|--------|--------------------------------------|---------|
| 0-10   | Overburden                           |         |
| 10-23  | Clay                                 |         |
| 23-38  | Sand & Gravel                        |         |
| 38-70  | Clay - Green                         |         |
| 70-96  | Shells & black sand                  |         |
| 96-120 | Clay - brown                         |         |
| 20-160 | Shells                               |         |
| 60-195 | Clay - blue                          |         |
| 95-215 | Sand - Grey - water bearing          |         |
| 15-235 | Clay                                 |         |

I certify that the information contained here is true and that this well was installed and constructed accordance with the permit and further that the well complies with all applicable state and lo. regulations, ordinances and laws.

**Drilling**

Contractor Van's Construction Co., Inc.  
 Address P.O. Box 3306  
Fredericksburg, Va 22402  
 Phone 703-373-7502

Drillers Signature *John Slator* Date 9-28-93  
 Representing Van's Construction Co., Inc.  
 Virginia Contractors License Number 2701-028610A